

## **Electricity Supplied Under The Jag Mag Yojna**

**\*97. Sh. JAIVEER SINGH M.L.A.:**

Will the Power Minister be pleased to state the number of villages of Kharkhoda assembly Constituency in which 24 hours electricity is being supplied under the Jag Mag Yojna?

**Ranjit Singh, Power Minister**

Sir,

At present, no village of Kharkhoda Assembly Constituency has been provided 24 Hrs supply under Mahara Gaon jagmag Gaon Scheme.

### NOTE FOR PAD

There are 45 villages in Kharkoda Assembly Constituency. Out of these 45 villages, 01 village namely Sohti on 11 KV Sohti-1 RDS Feeder after completion of work under MGJG Scheme was allowed 24 Hrs supply w.e.f 15.08.2019 in Kharkoda Assembly Constituency. But, due to high line losses and hindrance by villagers in the work of Meter Reading and collection of the bills, the supply was reduced from 24 Hrs to 16 Hours on dated 04.11.2019. Details of Line losses of 23 RDS feeders having 45 villages in Kharkhoda Assembly Constituency are as under:-

Sr. No.	Name of 11 KV RDS Feeder	April to December 2019			Name of Villages on 11 KV RDS Feeder
		Units Received. (In Lus)	Units Billed (In Lus)	Line losses in % Age	
1	Mandora	94.00	8.81	90.63	Chota Thana, Turkpur, Mandora, Mandori
2	Silana	55.89	6.07	89.14	Silana
3	Bhadana	99.20	13.15	86.74	Kakroi, Bhadana, Kheri Dahiya
4	Thana Kalan	53.16	8.02	84.91	Thana Kalan
5	Ferojpur	53.23	8.93	83.22	Ferojpur, Jhinjoli
6	Saidpur	67.93	11.47	83.12	Saidpur, Jatola
7	Sisana	99.10	16.74	83.11	Sisana, Phoolgarh
8	Garhi Sisana	33.74	5.71	83.08	Garhi Sisana
9	Bidhlan	53.00	9.28	82.49	Bidhlan, Sehri
10	Kidholi	47.30	8.45	82.14	Pai, Kidholi, Parhladpur
11	Nakloi	34.41	6.21	81.95	Nakloi, Nithan
12	Sohti -1	30.80	5.95	80.68	Sohti
13	Kundal	53.21	10.54	80.19	Kunal, Rampur, Nizampur Khurd
14	Barona	103.93	22.20	78.81	Rohna
15	Khanda	80.02	17.27	78.42	Khanda, Chaulka
16	Matindu	36.64	8.02	78.11	Matindu, Chhinoli
17	Jharoth	71.50	16.80	76.50	Jharoth, Anandpur, Jharothi, Kanwali
18	Farmana	92.20	23.34	74.68	Farmana
19	Fatehpur	31.68	8.57	72.95	Rohat, Fatehpur
20	Humayupur	96.50	26.94	72.08	Gorar

21	Halalpur	61.06	17.41	71.49	Katlupur
22	Ridhau	31.07	8.91	71.32	Ridhau, Mojamnagar
23	Gopalpur	45.23	14.56	67.81	Pipli, Gopalpur

Mhara Gaon Jagmag Gaon (MGJG) scheme was launched in the State on 01.07.2015. The aim of the scheme is to provide electricity to the villagers on the urban pattern. Following activities are being carried out in the villages to improve the quality of service to consumers :

- i) Replacement of bare conductor with AB cable.
- ii) Replacement of defective/electro mechanical meters.
- iii) Shifting of meters outside the premises.
- iv) Maintenance of DT's.
- v) Maintenance of LD system
- vi) While replacement/relocation of meter as a onetime measure, the meter would be replaced on the spot without further checking from the M&T Lab.

At present, 24 hours supply is being given on 1048 Nos. 11 KV RDS feeders covering 4463 villages in the State after completion of work under MGJG scheme. 24 Hours supply is being provided to all villages of District namely Ambala, Panchkula, Yamuna Nagar, Kurukshetra, Faridabad, Gurugram, Rewari, Sirsa & Fatehabad. The details are as under: -

Sr.No.	Name of District	24 Hours Supply	
		Nos. Of Feeders	Nos. Of Villages
1	Ambala	51	273
2	Panchkula	20	342
3	Kurukshetra	98	412
4	Karnal	129	408
5	Y/Nagar	98	920
6	Panipat	8	20
7	Rohtak	9	10
8	Jhajjar	8	21
9	Sonipat	33	66

10	Kaithal	74	165
	<b>UHBVN</b>	<b>528</b>	<b>2637</b>
11	Faridabad	31	135
12	Palwal	1	3
13	Mewat	1	1
14	Gurgaon	59	250
15	Rewari	84	418
16	Mahendergarh (Narnaul)	38	187
17	Fatehabad	99	300
18	Bhiwani	44	134
19	Charkhi-Dadri	0	0
20	Hisar	18	43
21	Sirsa	144	354
22	Jind	1	1
	<b>DHBVN</b>	<b>520</b>	<b>1826</b>
	<b>State as a whole</b>	<b>1048</b>	<b>4463</b>

As and when villagers of any 11 KV RDS feeder in Kharkhoda Assembly constituency comes forward to adopt MGJG Scheme, the Nigam would readily undertake system strengthening works and provide 24 hours supply as per Government scheme to the consumers.