

To replace the Vacuum Circuit Breaker.

682 Sh. Sita Ram Yadav, M.L.A: Will the Power Minister be pleased to state:-

- a) whether it is a fact that the vacuum circuit breakers in all the 132KV power houses of Ateli Assembly Constituency has been failed; and
- b) if so, whether there is any proposal under consideration of the Government to replace the vacuum circuit breakers in abovesaid power houses togetherwith the time by which these are likely to be replaced?

Ranjit Singh, Power Minister

- a) No, Sir. All Vacuum Circuit Breakers (VCBs) are in working position. However, old VCBs are to be replaced in a phased manner.
- b) The following VCBs has been replaced/to be replaced:-

Sr. No.	Name of Sub-Station	Description	No. of VCBs	Status of replacement
1.	Ateli Mandi	T1, 10/16 MVA T/F	13 Nos.	Replaced on 25.03.2021
		T2, 16/20 MVA T/F	12 Nos.	To be Replaced in FY 2022-23
2.	Mudiakhera	T1, 10/16 MVA T/F	13 Nos.	Replaced on 27.04.2021
3.	Kanina	T2 10/16 MVA T/F	9 Nos.	To be Replaced in FY 2022-23
		T4 16/20 MVA T/F	11 Nos.	Healthy condition

वैक्यूम सर्किट ब्रेकरों को बदलना

- 682. श्री सीता राम यादव, एम.एल.ए.:** क्या बिजली मंत्री कृपया बताएं कि:—
- (क) क्या यह तथ्य है कि अटेली विधानसभा निर्वाचन क्षेत्र के 132 के० वी० बिजली घरों में वैक्यूम सर्किट ब्रेकर विफल हो गए हैं; तथा
- (ख) यदि हां, तो उपरोक्त बिजली घरों में वैक्यूम सर्किट ब्रेकर बदलने का कोई प्रस्ताव सरकार के विचाराधीन है; यदि हां, तो इनके कब तक बदले जाने की संभावना है?

रणजीत सिंह, बिजली मंत्री

- (क) नहीं, श्रीमान। सभी वैक्यूम सर्किट ब्रेकर (वीसीबी) चालू स्थिति में है। हालांकि, पुराने वैक्यूम सर्किट ब्रेकरों को चरणबद्ध ढंग से बदला जाना है।
- (ख) निम्नलिखित वैक्यूम सर्किट ब्रेकरों को बदला गया/बदला जाना है:—

क्र. सं.	सब-स्टेशन का नाम	विवरण	वीसीबी की संख्या	बदलने की स्थिति
1.	अटेली मण्डी	टी1, 10 / 16 एमवीए ट्रांसफार्मर	13	25.03.2021 को बदला गया
		टी2, 16 / 20 एमवीए ट्रांसफार्मर	12	वित्त वर्ष 2022-23 में बदला जाना है
2.	मुंडियाखेड़ा	टी1, 10 / 16 एमवीए ट्रांसफार्मर	13	27.04.2021 को बदला गया
3.	कनीना	टी2, 10 / 16 एमवीए ट्रांसफार्मर	9	वित्त वर्ष 2022-23 में बदला जाना है
		टी4, 16 / 20 एमवीए ट्रांसफार्मर	11	अच्छी स्थिति में